



EC CERTIFICATE

Notified Body No. 0843

CPR Notified Body UL International (UK) Ltd., Wonersh House, The Guildway, Old Portsmouth Road, Guildford, Surrey, GU3 1LR, United Kingdom

Certificate of constancy of performance 0843-CPR-0474

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Knauf FPM - fire protection mortar Penetration Seal Classified for use in flexible & solid walls and solid floors

A mortar used to seal around cables and metallic pipes to form a penetration seal to reinstate the fire resistance performance of wall and floor constructions, where they have been provided with apertures for the penetration of services. Knauf FPM – fire protection mortar is supplied as a dry material, and is mixed with water to the required ratio prior to installation.

placed on the market under the name or trade mark of

Knauf Sp. Z o.o.
ul. Światowa 25, 02-229 Warsaw, Poland

and produced in the manufacturing plant(s)

A/003

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the

ETA 18/0929, issued on 12/12/2018

and

EAD 350454-00-1104, September 2017

under system AVCP 1 for the performance set out in the ETA are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 12th December 2018 and will remain valid as long as neither the ETA, the EAD, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body..

12th December 2018

Mr. Chris Johnson, Staff Engineer



EC CERTIFICATE

Notified Body No. 0843

CPR Notified Body UL International (UK) Ltd., Wonersh House, The Guildway, Old Portsmouth Road, Guildford, Surrey, GU3 1LR, United Kingdom

Annex: Detailed information sheet

Certificate Number: 0843-CPR-0474

Product/Device description: Knauf FPM - fire protection mortar

Applicant designation: Knauf Sp. Z o.o., ul. Światowa 25, 02-229 Warsaw, Poland

Product Information

Knauf FPM - fire protection mortar

The referenced product complies with:

A – All the relevant requirements as per ETA 18/0929

ETA issue dates:

ETA 18/0929, issued 12/12/2018

12th December 2018

Mr. Chris Johnson, Staff Engineer