



designated according to Article 29 of the Regulation (EU) No 305/2011 and member of EOTA (European Organisation for Technical Assessment, [www.eota.eu](http://www.eota.eu))

## European Technical Assessment

**ETA 23/0975  
of 29/02/2024**

**Technical Assessment Body issuing the ETA and designated according to Article 29 of the Regulation (EU) No 305/2011: UL International (Netherlands) B.V.**

**Trade name of the construction product**

Knauf FPA Acrylic

**Product family to which the construction product belongs**

Fire Stopping and Sealing Product:  
• Penetration Seals

**Manufacturer**

Knauf Sia  
Daugavas iela 4,  
Saurieši, Stopiņu pagasts,  
Ropažu novads, LV-2118,  
Latvija

**Manufacturing plant(s)**

A/003

**This European Technical Assessment contains**

95 pages including 1 Annex which forms an integral part of this assessment.

**This European Technical Assessment is issued in accordance with regulation (EU) No 305/2011, on the basis of**

EAD 350454-00-1104, September 2017.

Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and should be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may be made, with the written consent of the issuing Technical Assessment Body. Any partial reproduction has to be identified as such.

## **Table of Contents**

|           |   |           |
|-----------|---|-----------|
| <b>I.</b> | <b>SPECIFIC PARTS OF THE EUROPEAN TECHNICAL ASSESSMENT.....</b>   | <b>3</b>  |
| 1         | Technical description of the product .....  | 3         |
| 2         | Specification of the intended uses of the product in accordance with the applicable European Assessment Document (Hereinafter EAD): EAD 350454-00-1104: 2017..... | 3         |
| 3         | Performance of the product and references to the methods used for its assessment.....   | 6         |
| 4         | ASSESSMENT AND VERIFICATION OF CONSTANCY OF PERFORMANCE (HEREINAFTER AVCP) SYSTEM APPLIED, WITH REFERENCE TO ITS LEGAL BASE.....                                  | 7         |
| 5         | Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD.....   | 7         |
| 6         | Issued on:.....   | 8         |
|           | <b>ANNEX A – Resistance to Fire Classification – Knauf FPA Acrylic.....</b>   | <b>9</b>  |
| A.1       | Rigid wall constructions according to 1.2.1 with wall thickness of minimum 150 mm.....  | 9         |
| A.1.1     | Single side penetration seal with cables .....  | 9         |
| A.1.2     | Double side penetration seal with cables .....  | 10        |
| A.1.3     | Single side penetration seal with metallic (and composite) pipes.....   | 11        |
| A.1.4     | Single side penetration seal with metallic (and composite) pipes.....   | 13        |
| A.1.5     | Single side penetration seal with metallic pipes .....  | 15        |
| A.1.6     | Double side penetration seal with metallic pipes .....  | 17        |
| A.1.7     | Double side penetration seal with metallic pipes .....  | 19        |
| A.1.8     | Double side penetration seal with metallic pipes with combustible insulation .....  | 21        |
| A.1.9     | Double side penetration seal with plastic pipes.....  | 23        |
| A.2       | Flexible and rigid wall constructions according to 2. 2) with wall thickness of minimum 75 mm.....  | 25        |
| A.2.1     | Double side penetration seal with cables .....  | 25        |
| A.3       | Flexible and rigid wall constructions according to 2.2) with wall thickness of minimum 100 mm.....  | 29        |
| A.3.1     | Double side penetration seal with cables .....  | 29        |
| A.3.2     | Double side penetration seal with metallic pipes .....  | 31        |
| A.3.3     | Double side penetration seal with metallic pipes .....  | 37        |
| A.3.4     | Double side penetration seal with composite pipes .....   | 42        |
| A.3.5     | Double side penetration seal with metallic (and composite) pipes.....   | 43        |
| A.3.6     | Double side penetration seal with plastic pipes.....  | 46        |
| A.4       | Flexible and rigid wall constructions according to 2.2) with wall thickness of minimum 120 mm.....  | 48        |
| A.4.1     | Double side penetration seal with cables .....  | 48        |
| A.5       | Timber wall constructions with wall thickness of minimum 100 mm.....  | 49        |
| A.5.1     | Double side penetration seal with cables .....  | 49        |
| A.5.2     | Double side penetration seal with cables and Knauf FPC Service Coating .....  | 50        |
| A.5.3     | Double side penetration seal with metallic pipes .....  | 51        |
| A.5.4     | Double side penetration seal with metallic pipes .....  | 54        |
| A.5.5     | Double side penetration seal with plastic pipes and composite pipes.....  | 57        |
| A.6       | Rigid floor constructions according to 1.2.1 with floor thickness of minimum 150 mm.....  | 60        |
| A.6.1     | Single side penetration seal with cables .....  | 60        |
| A.6.2     | Single side penetration seal with cables .....  | 62        |
| A.6.3     | Single side penetration seal with pipes.....  | 63        |
| A.6.4     | Double side penetration seal with pipes.....  | 67        |
| A.6.5     | Double side penetration seal with cables .....  | 69        |
| A.6.6     | Single side penetration seal with metallic pipes .....  | 70        |
| A.6.7     | Single side penetration seal with metallic pipes .....  | 74        |
| A.6.8     | Single side penetration seal with metallic pipes .....  | 76        |
| A.6.9     | Single side penetration seal with composite pipes .....   | 77        |
| A.6.10    | Double side penetration seal with metallic pipes .....  | 78        |
| A.6.11    | Double side penetration seal with metallic pipes .....  | 80        |
| A.6.12    | Double side penetration seal with metallic pipes .....  | 85        |
| A.7       | Timber floor constructions with floor thickness of minimum 150 mm .....   | 87        |
| A.7.1     | Double sided penetration seal with cables .....   | 87        |
| A.7.2     | Double side penetration seal with metallic pipes .....  | 89        |
| A.7.3     | Double side penetration seal with plastic pipes and composite pipes.....  | 92        |
|           | <b>ANNEX B – Air Permeability – Knauf FPA Acrylic.....</b>  | <b>95</b> |

I. **SPECIFIC PARTS OF THE EUROPEAN TECHNICAL ASSESSMENT**

1 **Technical description of the product**

- 1) Knauf FPA Acrylic is a sealant used to form a penetration seal around metallic pipes, plastic pipes, composite pipes, combustible cable conduits and electrical cables to reinstate the fire resistance performance of wall and floor constructions, where they have been provided with apertures for the penetration of services.
- 2) The Knauf FPA Acrylic is supplied in liquid form contained within 310 & 380 ml cartridges and 300 to 600 ml foil packs. The sealant is gunned into the aperture in the separating element/elements and around the service or services, to a specified depth utilising mineral fibre insulation backing material.
- 3) Knauf FPA Acrylic contains no carcinogenic substances or mutagenic substances, flame retardants or antimicrobiological agents.
- 4) The applicant has submitted a written declaration that Knauf FPA Acrylic does not contain substances which have to be classified as dangerous according to Directive 67/548/EEC and Regulation (EC) No 1272/2008 and listed in the "Indicative list on dangerous substances" of the EGDS - taking into account the installation conditions of the construction product and the release scenarios resulting from there. An emission report has also been provided.

In addition to the specific clauses relating to dangerous substances contained in this European technical Assessment, there may be other requirements applicable to the products falling within its scope (e.g. transposed European legislation and national laws, regulations and administrative provisions). In order to meet the provisions of the Construction Products Regulation, these requirements need also to be complied with, when and where they apply.

- 5) The use category of Knauf FPA Acrylic in relation to BWR 3 (Hygiene, health and environment) is IA1, S/W2

2 **Specification of the intended uses of the product in accordance with the applicable European Assessment Document (Hereinafter EAD): EAD 350454-00-1104: 2017**

Detailed information and data is given in Annex A.

- 1) The intended use of system Knauf FPA Acrylic is to reinstate the fire resistance performance of flexible wall constructions, rigid wall constructions and rigid floor constructions where they are penetrated by various metal pipe services with and without combustible insulation, plastic pipes, combustible cable conduits, composite pipes and electrical cables.
- 2) The specific elements of construction that the system Knauf FPA Acrylic may be used to provide a penetration seal in, are as follows:
  - a. Flexible walls: The wall must have a minimum thickness of 75 mm and comprise steel studs or timber studs\* lined on both faces with minimum 1 layer of 12.5 mm thick boards. Flexible wall solutions may also be used in rigid walls, with a minimum density of 350 kg/m<sup>3</sup>.
  - b. Timber walls: The wall must have a minimum thickness of 100 mm and comprise solid wood or cross-laminated timber.

- c. Rigid walls: The wall must have a minimum thickness of 75 mm and comprise concrete, aerated concrete or masonry, with a minimum density of 650 kg/m<sup>3</sup>.
- d. Rigid floors: The floor must have a minimum thickness of 150 mm and comprise aerated concrete or concrete with a minimum density of 650 kg/m<sup>3</sup>.
- e. Timber floors: The floor must have a minimum thickness of 150 mm and comprise solid wood or cross-laminated timber.

\* no part of the penetration seal may be closer than 100 mm to a stud, the cavity must be closed between the penetration seal and the stud, and minimum 100 mm of insulation of class A1 or A2 according to EN 13501-1 must be provided within the cavity between the penetration seal and the stud.

The supporting construction must be classified in accordance with EN 13501-2 for the required fire resistance period.

Knauf Sia Fire Protection Systems which involve services penetrating both sides of a flexible wall may also be used in the situation where the services penetrates one side of the wall only and the remaining side of the wall is not penetrated at the same point (i.e. the services continues on the inside of the wall). All fire integrity and thermal insulation ratings for such single-sided penetrations remain the same as for the equivalent double-sided penetration.

- 3) The system Knauf FPA Acrylic may be used to provide a penetration seal with specific single insulated metal pipes, uninsulated metal pipes, plastic pipes, combustible cable conduits, composite pipes and with specific electrical cables, single or in a bundle (for details see Annex A).
- 4) Apertures in the separating element shall be maximum  $\varnothing$  504 mm, 300 x 300 mm or 100 x 1000 mm. The annular space/gap around the services shall be infilled with Knauf FPA Acrylic sealant and in some cases a mineral fibre insulation backing material. Blank seals up to 300 x 300 mm are permitted. For full details, see Annex A.
- 5) Pipes shall be supported at maximum 350 mm away from both faces of the wall constructions and 550 mm from the upper face of floor constructions.
- 6) Where a backing material is described in Annex A, this can be replaced with Knauf FPA Acrylic if the total seal depth is the same or greater.
- 7) Where single sided top face seals are described in Annex A, these can also be used in composite floors if the thickness of the concrete where the seal is placed is the same or greater than the required depth of the fire seal.
- 8) Where PVC pipes are mentioned in Annex A, this includes PVC-U, PVC-C and similar if the pipe is according to EN 1329-1, EN 1452-2, EN 1453-1<sup>^</sup> and EN 1566-1. Where PP pipes are mentioned in Annex A, this includes PP-MV, PP-H, PP-R and similar if the pipe is according to EN 1451-1 or DIN 8077/8078. Where PE pipes are mentioned, this includes PE-LD, PE-MD, PE-HD, PE-X and similar according to EN 1519-1, EN 12201-2 or EN 12666-1, ABS according to EN 1455-1 and pipes made from SAN+PVC according to EN 1565-1.
- 9) An aperture with or without penetrating services, fire sealed with the system Knauf FPA Acrylic, can include a steel or plastic sleeve casted or friction fitted within rigid constructions. The plastic sleeve should have a maximum wall thickness of 14.6 mm.

- 10) Services through the system Knauf FPA Acrylic may be used in all angles between 90° and 45° in all directions, subject to metallic pipes only.
- 11) The provisions made in this European Technical Approval are based on an assumed working life of the Knauf FPA Acrylic of 25 years, provided that the conditions laid down in the manufacturers datasheet and instructions for the packaging/transport/ storage/installation/use/repair are met. The indications given on the working life cannot be interpreted as a guarantee given by the producer but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.
- 12) Type Z<sub>2</sub>: Intended for uses in internal conditions with humidity lower than 85 % RH excluding temperatures below 0°C, without exposure to rain or UV.

### 3 Performance of the product and references to the methods used for its assessment

| Product-type: Sealant  |  | Intended use: Penetration Seal                           |  |
|--|--|--|--|
| Basic requirement for construction work  | Essential characteristic                                 | Performance  |  |
| <b>BWR 2 Safety in case of fire</b>  |  |  |  |
| EN 13501-1   | Reaction to fire   | Class B-s1, d0   |  |
| EN 13501-2   | Resistance to fire                                       | Annex A  |  |
| <b>BWR 3 Hygiene, health and environment</b>   |  |  |  |
| EN 1026  | Air permeability   | Annex B  |  |
| EAD 350454-00-1104, Annex C  | Water permeability                                       | No performance determined                                |  |
| Declaration of manufacturer & EN 16516   | Content, emission and/or release of dangerous substances | Use categories: IA1, S/W2<br>Declaration of manufacturer |  |
| <b>BWR 4 Safety in use</b>   |  |  |  |
| EOTA TR 001:2003   | Mechanical resistance and stability                      | No performance determined                                |  |
| EOTA TR 001:2003   | Resistance to impact/movement                            | No performance determined                                |  |
| EOTA TR 001:2003   | Adhesion   | No performance determined                                |  |
| EAD 350454-00-1104, Clause 2.2.9   | Durability   | Z <sub>2</sub>   |  |
| <b>BWR 5 Protection against noise</b>  |  |  |  |
| EN 10140-1,2,4,5/ EN ISO 717-1   | Airborne sound insulation                                | Rw(C;Ctr)= 62 (-1;-5) dB*                                |  |
| <b>BWR 6 Energy economy and heat retention</b>   |  |  |  |
| EN 12664, EN 12667, EN 12939, EN ISO 8990, EN ISO 6946, EN ISO 14683, EN ISO 10211, EN ISO 10456 | Thermal properties                                       | No performance determined                                |  |
| EN ISO 12572, EN 12086, EN ISO 10456   | Water vapour permeability                                | No performance determined                                |  |

\* At 12 mm depth

**4 ASSESSMENT AND VERIFICATION OF CONSTANCY OF PERFORMANCE (HEREINAFTER AVCP) SYSTEM APPLIED, WITH REFERENCE TO ITS LEGAL BASE**

According to the decision 1999/454/EC – Commission Decision of date 22nd June 1999 on the procedure for attesting the conformity of construction products pursuant to Article 20(2) of Council Directive 89/106/EEC as regards fire stopping, fire sealing and fire protective products, published in the Official Journal of the European Union (OJEU) L178/52 of 14/07/1999, (see <https://eur-lex.europa.eu/oj/direct-access.html>) of the European Commission<sup>1</sup>, as amended, the system(s) of assessment and verification of constancy of performance (see Annex V to Regulation (EU) No 305/2011) given in the following table(s) applies (apply).

| Product(s)                              | Intended use(s)  | Level(s) or class(es) | System(s) |
|---|--|-----------------------|-----------|
| Fire stopping and Fire Sealing Products | For fire compartmentation and/or fire protection or fire performance | Any                   | 1         |

**5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD**

**Tasks of the manufacturer:**

Factory production control

The manufacturer shall exercise permanent internal control of production. All the elements, requirements and provisions adopted by the manufacturer shall be documented in a systematic manner in the form of written policies and procedures, including records of results performed. This production control system shall ensure that the product is in conformity with this European Technical Assessment.

The manufacturer may only use initial / raw / constituent materials stated in the technical documentation of this European Technical Assessment.

The factory production control shall be in accordance with the Control Plan of 7<sup>th</sup> February 2023 relating to the European Technical Assessment ETA 23/0975 issued on 29/02/2024 which is part of the technical documentation of this European Technical Assessment. The "Control Plan" is laid down in the context of the factory production control system operated by the manufacturer and deposited at UL International (Netherlands) B.V.

The results of factory production control shall be recorded and evaluated in accordance with the provisions of the Control Plan.

---

<sup>1</sup> Official Journal of the European Communities L178/52 of 14/7/1999

**Other tasks of the manufacturer:**

Additional information

The manufacturer shall provide a technical data sheet and an installation instruction with the following minimum information:

- (a) Technical data sheet:
- Field of application:
  - Building elements for which the penetration seal is suitable, type and properties of the building elements like minimum thickness, density, and - in case of lightweight constructions – the construction requirements.
  - Limits in size, minimum thickness etc. of the penetration seal
  - Construction of the penetration seal including the necessary components and additional products (e.g. backfilling material) with clear indication whether they are generic or specific.
  - Services which the penetration seal is suitable, type and properties of the services like material, diameter, thickness etc. in case of pipes including insulation materials; necessary/allowed supports/fixings (e.g. pipe trays)
- (b) Installation instruction:
- Steps to be followed
  - Procedure in case of retrofitting
  - Stipulations on maintenance, repair and replacement

**6 Issued on:**

**29<sup>th</sup> February 2024**

Report by:



D. Yates  
Staff Engineer  
Built Environment

Verified by:



C. Johnson  
Senior Staff Engineer  
Built Environment

Validated by:



Erik Teubler  
Head of TAB  
Built Environment

For and on behalf of UL International (Netherlands) B.V.